

Evaluation and Enhancement of Potential Severn Barrage Schemes

IET Power Academy Seminar
Cardiff 2012



Al-Mansoor Amin, Geraint Chaffey, Jack Lawthom, Darrell Milman

Background

- * Most recent review in 2010 for DECC
- * Renewed interest in Severn tidal generation from private investors
- * New estimated connection date of 2030

Project Aims

- * Review previous proposals
- * Develop 2018 model
- * Investigate 2030 model
 - * Uncertain energy future scenario
- * Add Severn Barrage to model
- * Investigate the effect of the Severn Barrage
- * Investigate required network reinforcement
- * Determine economic feasibility

Schemes Selected for DECC Study



- A: Beachley Barrage
- B: Shoots Barrage
- C: Welsh Grounds Lagoon
- D: Cardiff-Weston Barrage
- E: Bridgewater Bay Lagoon

Project Cost

- Based on a previous model (Parson's Brinkerhoff)
- Project cost split into following areas:
 - PRE-CONSTRUCTION = 1%
 - CONSTRUCTION & GENERAL CIVILS = 12.5 %
 - CAISSONS = 25.5%
 - M&E = 36%
 - ADDITIONAL ITEMS = 5.5%
 - COMPENSATORY HABITATS = 19%
 - PROMOTIONAL COST = 0.5%
- Inflation Rate

Benefits

- * Renewable Obligation Certificates
- * Severn Obligation Certificates
- * Feed-in-Tariff
 - * 7.8p/kWh
- * Annual income £1.3bn

NPV Study


- * Base Year = 2012
- * Length of study 120 years
- * Discount rate of 8%
- * NPV = -£7.747bn

- * Promote interest through more incentives



Simulated UK Transmission Network


- * Power System Analysis CAD
- * Quasi-geographical one line diagram
- * National Grid Transmission Assets (275/400kV)




Transmission System Modelling to 2018

- * Automated update process using Excel macros
- * National Grid data was converted to a Neplan compatible format
- * Unique Neplan compatible names were generated for new additions
- * Process is easily repeatable for different scenarios and future users

Cardiff-Weston Barrage Connection with Circuits Across Barrage



Addition of the Barrage




2030 scenario implementation


- * 10% load increase (Electrify all sectors)
- * 15% of electricity from DG (Low energy demand)
- * Large amount of wind (Renewable generation)
- * Centralised generation (Nuclear generation)

Power System Analysis

- * DC Load Flow
 - * Balancing
 - * Capacity Requirements
- * Extended Newton Raphson Load Flow
 - * Power Flows
 - * Voltage levels




Implementation: NPL



- * C++ based interface
- * Automated network modification and testing
- * Programs written
 - * Balance network
 - * Find ideal network configuration
 - * Line up-rating
 - * Load flow contingency testing

HVDC Barrage



HVDC Converter Parameters	
Fir.=22.24 deg Ratio=1.250 Cntrl 1=Vd Cntrl 2=NONE	Fir.=15.00 deg Ratio=1.250 Cntrl 1=Pd Cntrl 2=NONE
Fir.=22.24 deg Ratio=1.250 Cntrl 1=Vd Cntrl 2=NONE	Fir.=15.00 deg Ratio=1.250 Cntrl 1=Pd Cntrl 2=NONE


Modelling Method

- * Balance network
 - * Load & Generation according to scenario
- * Reinforce network to required capacity
 - * Line up-rating to required capacity
- * Simulate outage conditions
 - * Reinforce in order to meet outage requirements


Contingency testing

- * Entire network:
 - * 571 transmission lines
 - * 'n - 1' = 571 combinations
 - * 'n - 2' \approx 200,000 combinations
 - * 4 scenarios, with and without barrage
 - * 1.6 million simulations
- * Reinforcement
 - * Security & Quality of Supply Standards


Wind Scenario – No Barrage



Wind Scenario – With Barrage




National Grid Study Zones




Wind Scenario – Zones 13 & 17

No Barrage




With Barrage




Wind Scenario – Zones 13 & 17


Hinkley Point: No Barrage




Hinkley Point: With Barrage



Ironbridge – Mid West Wales: No Barrage




Hinkley Point – Weston: With Barrage




All Scenario Results – Box Plot




All Scenario Results – Box Plot




Tidal Range and Electricity Demand



Normal Ebb Operation – 14th Jan 2011



Delayed Ebb Operation – 12th Jan 2011



Delayed Operation

- * Offset carbon intensive generation
- * Fast demand response
- * High price of electricity
- * Lower energy output
- * Carbon saving?
- * Limited opportunities

12th & 14th January

- * Normal operation: ~4.03 GWh
- * Delayed operation: ~3.18Gwh

Conclusions

- * Financial feasibility relies on government support
 - * Key asset for 2050 targets
- * Proposed new mode of operation
 - * Potential carbon savings
- * Software framework for future use
 - * Statistical analysis of power systems possible
- * Modern conductor technologies allow 'n-2' contingency with barrage connected