

## NEPLAN® Protection Assessment


Reliable and improved solution for power system protection

<b>Challenges</b>	Co-ordination of protection devices for all types of faults and different network loading and topology states
<b>Customer</b>	Large transmission and distribution utilities especially with renewable energy integration in LV networks due to their unseen behavior
<b>Advantages</b>	To have a reliable protection system ensuring proper selectivity and sensitivity for all relay settings
<b>Solution</b>	Automatic assessment with clear indication of relays that are not selective and faults that are not cleared


### Need for Assessment

- Operation of protection devices ensuring reliability and selectivity
- Dependability: Must operate when required
- Security: Should not operate unnecessarily
- Risk of nuisance relay tripping which may lead to blackout
- Optimal relay settings for:
  - All types of faults
  - Different loading states
  - Different topology states
- Different relay co-ordination philosophies

### RELAY SETTING ASSESSMENT



### Why NEPLAN?




### Features

- Sequential and simultaneous automatic simulation for all fault scenarios
- Multiple loading and topology states can be simulated simultaneously
- Partial selection of the network bases on voltage level, area, zone, feeder, etc.
- User-defined scanning distance for fault on lines and user-defined minimum co-ordination time
- Tripping sequence of protection devices
- Report non-selective relays and non-cleared faults
- Fault path visualization on the single line diagram

## Sequential Assessment

- Simulation of one fault location at a time
- List of all protection devices based on their tripping time
- Sequence of operation of the protection devices
- Along with tripping, all currents and impedances seen by the relay are reported
- As an option, Unfed part of the network due to the fastest tripping devices can be visualized in the diagram
- Intuitive user-interface to simulate faults throughout the network

Name	Trip time [s]	Ik" [kA]	Ik"Ang [°]	Z [Ohms]	Z Ang [°]
DP 3.4	0	2.5063	103.4219	27.8735	76.5781
DP 3.1.2	0	2.0901	94.0857	33.4244	85.9143
DP 3.1.1	0	2.0901	94.0857	33.4244	85.9143
DP 4.3	0.4	2.5063	-76.5781	13.9296	265.8007
DP 1.3.1	1	2.0901	-85.9143	16.9902	-87.6099
DP 1.3.2	1	2.0901	-85.9143	16.9902	-87.6099
OC 4.3	1.3	2.5063	-76.5781	0	0
OC 1.3.1-1	3.4	2.0901	-85.9143	0	0
OC 1.3.2	3.4	2.0901	-85.9143	0	0
DP 1.2.2	5	0.1233	51.5074	287.9284	134.9684
DP 4.N24	5	0.2213	223.177	157.7902	-33.9543
DP 2.1.2	5	0.1233	231.5074	286.5963	-44.6365
DP 2.N24	5	0.2213	43.177	159.7552	143.6939
DP 1.2.1	5	0.1233	51.5074	287.9284	134.9684



## Automatic Assessment

- Simultaneous simulation of all possible fault types at busbars and sliding faults on lines
- User-defined scanning distance for fault on lines
- User-defined minimum co-ordination time between two protection devices
- All fault scenarios with non-selective relays or faults that are not cleared are reported
- Tripping sequence of protection devices for each fault scenario
- Visualization of the fault path on single line diagram
- All results can be exported to MS-EXCEL

- Fault is cleared and all relays are selective
- Fault is cleared but some relays are not selective
- Fault is cleared but some relays did not trip
- Fault is not cleared

Selection criteria	Variant	Voltage Level	Station			
Area	Zone	Feeder				
Network selection ...	Operational states ...	Fault types ...				
Scanning distance - %: 50	<input type="checkbox"/> Only bus faults	<input checked="" type="checkbox"/> Show all results				
Min. Co-ord. time - s: 0						
Assessment						
	Fault Location	Fault Type	Distance [%]	Operational State	Fault Path	Remark
+	1	3 Phase	0	Default	4 - 1	Selective
+	1	3 Phase	0	Default	4 - 1	Relays not selective: [DP 1.3.2]
+	1	3 Phase	0	Default	2 - 1	Relays not selective: [DP 1.2.1]
-	1	3 Phase	0	Default	2 - 1	Relays not selective: [DP 1.2.2]
Name	Type	Trip time [s]	Ik" [kA]	Z [Ohms]		
OC 2.1.2	OvercurrentRelais	2.5	1.3989	0		
DP 1.2.2	DistanceRelais	5	1.3993	49.9389		
DP 1.2.1	DistanceRelais	5	1.3993	49.9389		
DP 2.N24	DistanceRelais	0.2	2.7187	24.4804		
+	Line 1-2-2	3 Phase	50	Default	Net2 - Line 1-2-2	Fault still supplied by Net2
+	2	3 Phase	0	Default	Net2 - 2	Fault still supplied by Net2
+	Line 1-2-1	3 Phase	50	Default	Net2 - Line 1-2-1	Fault still supplied by Net2
+	4	3 Phase	0	Default	2 - 4	Selective